


25 Law Drive, STE 1, Fairfield, NJ 07004-3295 USA Telephone 973-575-9114 Fax 973-575-0013 Email: sales@controlinstruments.com Internet: www.controlinstruments.com



Specifications

0 to 100% Lower Flammable Limit (LFL) Calibration:

Sensor heated to 200°C (392°F) Operating Temperature Accuracy

 \pm 3% of full scale reading or 10% of applied gas whichever is greater.

Repeatability Within 1% of measurement range

Zero Stability \pm 1% in 30 days Span Stability ± 5% per year Cell Response Time Less than 1 second

Power Requirement 120 VAC +10% -15% 50/60 Hertz

400 Watts maximum, 230 VAC optional

12 to 21% oxygen in sample Oxygen

0 to 21% oxygen in sample (optional)

Fuel Requirements 99.99% prepurified Hydrogen **Fuel Consumption** 58 liters/day 40-45PSIG hydrogen Compressed Air 20 PSIG, regulated, clean, dry

Air Consumption 64 SCFH, 32 LITERS/minute including purge

Humidity Range 0% to 100% Relative Humidity Relays Four Form A redundant safety relays

Two Form A SPST relays

Six relays for: Warning; Danger; Fault; Relay functions

Air/Fuel; Calibration-in-Progress and

Service Needed

Alarm Function Adjustable alarm ranges

Analog Output Two 4-20mA, 275 Ω max., includes line

length

Digital Output RS-485 Serial, Modbus protocol

Flame Cell Material Hard-coat aluminum

Sample Train Material Hard-coat aluminum & stainless steel Flame Cell Rating Explosion Proof Class I, Division 1 Hazardous Area Rating Class I, Div 2, Groups A, B, C, D

Enclosure Rating TYPE 12/13, indoor

Assembly Dimensions

TYPE 4X, outdoor (optional) 16" H x 12.1" W x 8.5" D

FM (standard), FMc (optional)

Approvals

Approvals pending: CE, ATEX, IECEx, UKEX (optional)

SNR704 PrevEx® Flammability Analyzer

Analyzer Design

The Model SNR704 is an industrial strength assembly consisting of a heated flame cell and an integrated controller that continuously measures total flammable vapor concentrations from 0 to 100% of the Lower Flammable Limit (LFL) range. Optional modifications allow the SNR704 to sample low oxygen and inert atmospheres.

Control Instruments' proprietary flame temperature technology assures an accurate and linear response. A carefully metered pilot flame incinerates the sample; the resulting change in flame characteristics is proportional to the total concentration of flammable vapors present.

Heated Sampling System

To avoid condensation during sampling, the entire analyzer pneumatic assembly is heated to 200°C (392°F). This eliminates both inaccurate readings caused by solvent dropout as well as excessive maintenance time due to sample condensation and clogging. A concentric sampling probe further assures accurate, trouble-free sampling.

It is suitable for monitoring many common solvent vapors. The analyzer is unaffected by the temperature of the process and can sample streams above 1500°F.

The assembly mounts directly onto the process ductwork, as close as possible to the sample pickup point. This eliminates external heated sample lines and allows the fastest response time.

The analyzer employs customer-supplied compressed air to drive its integrated air-aspirated sampling system. This method is simple, has no moving parts and requires very little maintenance. The sampling system does not require bottled air or sample pumps.

Autocalibration solenoids, which allow remote activation of calibration tests, are standard.

Failsafe Operation

A fault relay de-energizes whenever any of the following occur: controller electrical failure; loss of system power; loss of heat; loss of flow through the flame cell; and downscale readings caused by loss of flame or fuel.

Outputs

The system includes six relays: four Form A redundant safety relays for Warning, Danger, Fault and Calibration-in-Progress and two Form A single-pole, single-throw relays for Service Needed and Air/Fuel cutoff. Other standard outputs include two 4-20mA analog outputs and an RS-485 serial port with Modbus protocol. Digital remote access and control is made possible with optional operator interface panels.

Performance

Detector response time is less than 1 second. The analyzer exhibits a very stable zero: less than one percent drift in thirty days. Calibration accuracy has less than five percent error per year.